



- NOTES:**
1. ALL DIMENSIONS & LEVELS ARE IN MM UNLESS OTHERWISE NOTED.
 2. ALL SPOT TYPE DETECTORS THAT NOT REQUIRE REMOTE LED WILL BE MOUNTED WITH ISOLATOR BASE.
 3. AN ISOLATOR MODULE BETWEEN EACH SPT TYPE DETECTOR WITH STANDARD BASE (CEILING AND FLOOR VOID DETECTORS).
 4. FOR ISOLATOR MODULES REFERS TO DRAWING: "M-ANM-3J1TS0-CFDA-SDR-200001".
 5. FINAL LOCATION OF FALSE CEILING MOUNTED DETECTORS WILL BE AS PER THE APPROVED REFLECTED CEILING PLAN.
 6. FIRE ALARM SCHEMATIC DIAGRAM WILL BE SUBMITTED SEPARATELY.
 7. SIZES OF THE HANDSETS, TELEPHONE, REMOTE LED AND WALL STATIONS AS PER APPROVED MATERIAL SUBMITTAL.

- REFERENCES OF DRAWINGS TO CONSULT:**
1. FOR LEGEND & USES OF EACH ENCLOSURE REFER TO: "M-ANM-3J1TS0-CKOO-SDR-000001".
 2. FOR ARCHITECTURE PLAN REFER TO DRAWING NO: "M-ANM-3J1TS0-CA00-EDR-200035".
 3. FOR ELEVATION & LONGITUDINAL SECTION, REFER TO DRAWING: "M-ANM-3J1TS0-CA00-EDR-200008".
 4. FOR CROSS SECTION, REFER TO DRAWING: "M-ANM-3J1TS0-CA00-EDR-200009".
 5. FOR REFLECTED CEILING PLAN, REFER TO DRAWING: "M-ANM-3J1TS0-CAIF-EDR-200006".
 6. FOR ISOLATOR MODULES REFER TO DRAWING: "M-ANM-3J1TS0-CFDA-SDR-000001".
 7. FOR ESCALATOR DETAIL, REFER TO DRAWING: "M-ANM-3J1TS0-CFDA-SDR-000001".
 8. FOR ELEVATOR DETAIL, REFER TO DRAWING: "M-ANM-3J1TS0-CFDA-SDR-000001".
 9. FOR FLOW SWITCH WITHOUT TIME DELAY, REFER TO DRAWING: "M-ANM-3J1TS0-CFDA-SDR-000001".
 10. FOR TAMPER SWITCH, REFER TO DRAWING: "M-ANM-3J1TS0-CFDA-SDR-000001".
 11. REFER TO SCHEMATIC RISER DIAGRAM FIRE ALARM LOOPS. "M-ANM-3J1TS0-CFDA-SDR-000021".
 12. REFER TO FIRE ALARM PLATFORM FLOOR LEVEL PLAN : "M-ANM-3J1TS0-CFDA-SDR-000010".
 13. FOR INSTALLATION REFER TO DRAWING: "M-ANM-3J1TS0-CFDA-SDR-000028".

P1	22.01.2018	ISSUED FOR REVIEW	M.F.
REV.	DATE	DESCRIPTION	APP.

PROJECT

RIYADH METRO PROJECT

PACKAGE 2

LINE 3



ORIGINATOR	CHECK	REVIEW	APPROVAL
SBS / P.K.	ARAIL / M.T.	ANM / P.I.	M.F.
DATE		SCALES	ORIGINAL SIZE A1
JANUARY 2018		A1= 1/400 A3= 1/800 0 10 20m	

DRAWING

TRANSFER STATION. SHOP DRAWING
3J1
MEP - ELECTRICAL SERVICES
PLATFORM LEVEL LINE 3 PLAN
FIRE ALARM. CEILING VOID DEVICE & EQUIPMENT

ANM DRAWING NUMBER	REVISION	SHEET
M-ANM-3J1TS0-CFDA-SDR-000009	P1	1 of 9
ALTERNATE DOCUMENT NUMBER	REVISION	SHEET
M-ANM-3J1TS0-CFDA-SDR-000009	P1	1 of 9